Alarms report 7.2019

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
01.07.2019, 10:33	43647440154,4792	1 (START)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
01.07.2019, 10:39	43647444317,5463	1 (START)	1082	Compressor block 2 is not ready
01.07.2019, 10:39	43647444329,1204	1 (START)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
01.07.2019, 10:40	43647444652,8819	0 (STOP)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
01.07.2019, 10:40	43647444652,8819	0 (STOP)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
01.07.2019, 11:04	43647461331,5046	0 (STOP)	1092	Condenser 2 is not ready
01.07.2019, 11:08	43647464003,1597	0 (STOP)	1082	Compressor block 2 is not ready
01.07.2019, 11:08	43647464014,7338	1 (START)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
01.07.2019, 11:08	43647464026,3773	1 (START)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
01.07.2019, 11:08	43647464072,6505	0 (STOP)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
01.07.2019, 11:08	43647464118,912	1 (START)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
01.07.2019, 11:08	43647464362,0718	0 (STOP)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
01.07.2019, 11:08	43647464396,7361	0 (STOP)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
01.07.2019, 15:02	43647626415,1852	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
01.07.2019, 15:18	43647637494,8843	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
01.07.2019, 16:14	43647677045,9491	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
01.07.2019, 16:48	43647700670,3241	1 (START)	1130	Compressor block 2 - Compressor 1 motor failure
02.07.2019, 08:17	43648345529,9653	0 (STOP)	1130	Compressor block 2 - Compressor 1 motor failure
02.07.2019, 08:18	43648345922,8935	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
06.07.2019, 07:24	43652308625,4977	0 (STOP)	1082	Compressor block 2 is not ready
06.07.2019, 07:24	43652308625,4977	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
06.07.2019, 07:24	43652308648,6343	0 (STOP)	1081	Compressor block 1 is not ready
06.07.2019, 07:24	43652308648,6343	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
06.07.2019, 07:24	43652308660,2431	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
06.07.2019, 07:24	43652308671,8171	0 (STOP)	1083	Compressor block 3 is not ready
06.07.2019, 07:33	43652314780,2778	0 (STOP)	1084	Compressor block 4 is not ready
06.07.2019, 07:33	43652314780,2778	0 (STOP)	1110	Compressor block 4 - phase monitor alarm
06.07.2019, 07:33	43652314838,1597	1 (START)	1154	Compressor block 4 - Fan of oil chiller alarm
06.07.2019, 07:45	43652323190,1273	0 (STOP)	1154	Compressor block 4 - Fan of oil chiller alarm
06.07.2019, 13:56	43652580932,1528	0 (STOP)	1082	Compressor block 2 is not ready
06.07.2019, 13:56	43652580932,1528	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
06.07.2019, 13:56	43652580967,0139	0 (STOP)	1081	Compressor block 1 is not ready
06.07.2019, 13:56	43652580967,0139	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
06.07.2019, 13:57	43652581925,9491	0 (STOP)	1093	Condenser 3 is not ready
06.07.2019, 13:58	43652581972,2685	0 (STOP)	1083	Compressor block 3 is not ready
06.07.2019, 13:58	43652581972,2685	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
06.07.2019, 14:02	43652585026,4815	0 (STOP)	1084	Compressor block 4 is not ready
06.07.2019, 14:02	43652585026,4815	0 (STOP)	1110	Compressor block 4 - phase monitor alarm
09.07.2019, 10:10	43655424181,1921	1 (START)	1082	Compressor block 2 is not ready
09.07.2019, 10:10	43655424296,956	1 (START)	1081	Compressor block 1 is not ready
09.07.2019, 10:12	43655425372,7778	0 (STOP)	1081	Compressor block 1 is not ready
09.07.2019, 10:12	43655425384,3287	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
09.07.2019, 10:12	43655425395,9144	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
09.07.2019, 10:20	43655430668,4722	1 (START)	1081	Compressor block 1 is not ready
09.07.2019, 10:23	43655432773,0556	0 (STOP)	1081	Compressor block 1 is not ready
09.07.2019, 10:29	43655436876,7708	1 (START)	1081	Compressor block 1 is not ready
09.07.2019, 10:32	43655439119,7338	0 (STOP)	1081	Compressor block 1 is not ready
09.07.2019, 10:32	43655439211,5394	0 (STOP)	1082	Compressor block 2 is not ready
26.07.2019, 13:43	43672572090,6134	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
26.07.2019, 14:16	43672594926,1343	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
26.07.2019, 15:13	43672634212,8009	1 (START)	1081	Compressor block 1 is not ready

Alarms report 7.2019

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
26.07.2019, 15:13	43672634485,625	0 (STOP)	1091	Condenser 1 is not ready
26.07.2019, 15:13	43672634508,7732	1 (START)	1091	Condenser 1 is not ready
26.07.2019, 15:14	43672635121,4468	0 (STOP)	1091	Condenser 1 is not ready
26.07.2019, 15:14	43672635179,3056	1 (START)	1091	Condenser 1 is not ready
26.07.2019, 15:31	43672647068,9699	0 (STOP)	1084	Compressor block 4 is not ready
26.07.2019, 15:31	43672647068,9699	0 (STOP)	1110	Compressor block 4 - phase monitor alarm
26.07.2019, 15:51	43672660716,5856	0 (STOP)	1091	Condenser 1 is not ready
26.07.2019, 15:51	43672661052,2801	0 (STOP)	1081	Compressor block 1 is not ready
28.07.2019, 13:51	43674577636,1343	1 (START)	1154	Compressor block 4 - Fan of oil chiller alarm
28.07.2019, 14:19	43674597030,1042	1 (START)	1148	Compressor block 4 - Compressor 2 motor failure
28.07.2019, 15:51	43674660869,8032	0 (STOP)	1148	Compressor block 4 - Compressor 2 motor failure
28.07.2019, 15:57	43674665262,3495	1 (START)	1084	Compressor block 4 is not ready
28.07.2019, 15:57	43674665262,3495	1 (START)	1110	Compressor block 4 - phase monitor alarm
28.07.2019, 15:57	43674665262,3495	0 (STOP)	1154	Compressor block 4 - Fan of oil chiller alarm
28.07.2019, 15:58	43674665366,25	1 (START)	1050	0.05 - Evaporator - electrical power is switched off
28.07.2019, 15:59	43674666025,7986	0 (STOP)	1110	Compressor block 4 - phase monitor alarm
28.07.2019, 15:59	43674666037,1412	0 (STOP)	1050	0.05 - Evaporator - electrical power is switched off
28.07.2019, 15:59	43674666037,1412	0 (STOP)	1084	Compressor block 4 is not ready
28.07.2019, 20:35	43674857823,1481	0 (STOP)	1082	Compressor block 2 is not ready
28.07.2019, 20:35	43674857823,1481	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
28.07.2019, 20:35	43674857880,9954	0 (STOP)	1083	Compressor block 3 is not ready
28.07.2019, 20:35	43674857880,9954	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
28.07.2019, 20:36	43674858389,4907	0 (STOP)	1081	Compressor block 1 is not ready
28.07.2019, 20:36	43674858389,4907	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
28.07.2019, 20:45	43674865269,8032	0 (STOP)	1084	Compressor block 4 is not ready
28.07.2019, 20:45	43674865269,8032	0 (STOP)	1110	Compressor block 4 - phase monitor alarm