Alarms report 1.2020

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
07.01.2020, 13:00	43264160961,794	1 (START)	1093	
23.01.2020, 09:26	43853393382,6042	1 (START)	1091	Condenser 1 is not ready
23.01.2020, 09:26	43853393382,6042	1 (START)	1092	Condenser 2 is not ready
23.01.2020, 09:26	43853393382,6042	1 (START)	1093	Condenser 3 is not ready
23.01.2020, 09:26	43853393382,6042	1 (START)	1081	Compressor block 1 is not ready
23.01.2020, 09:26	43853393382,6042	1 (START)	1082	Compressor block 2 is not ready
23.01.2020, 09:26	43853393382,6042	1 (START)	1083	Compressor block 3 is not ready
23.01.2020, 09:26	43853393382,6042	1 (START)	1084	Compressor block 4 is not ready
23.01.2020, 09:26	43853393382,6042	1 (START)	1107	Compressor block 1 - phase monitor alarm
23.01.2020, 09:26	43853393382,6042	1 (START)	1108	Compressor block 2 - phase monitor alarm
23.01.2020, 09:26	43853393382,6042	1 (START)	1109	Compressor block 3 - phase monitor alarm
23.01.2020, 09:26	43853393382,6042	1 (START)	1110	Compressor block 4 - phase monitor alarm
23.01.2020, 09:26	43853393382,6042	1 (START)	1100	Main power supply interrupted (U = 0 V)
23.01.2020, 09:26	43853393394,9537	0 (STOP)	1100	Main power supply interrupted (U = 0 V)
23.01.2020, 09:26	43853393439,5255	0 (STOP)	1091	Condenser 1 is not ready
23.01.2020, 09:26	43853393439,5255	0 (STOP)	1092	Condenser 2 is not ready
23.01.2020, 09:26	43853393439,5255	0 (STOP)	1093	Condenser 3 is not ready
23.01.2020, 09:30	43853395959,3519	0 (STOP)	1083	Compressor block 3 is not ready
23.01.2020, 09:30	43853395959,3519	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
23.01.2020, 09:37	43853401125,5324	0 (STOP)	1084	Compressor block 4 is not ready
23.01.2020, 09:37	43853401125,5324	0 (STOP)	1110	Compressor block 4 - phase monitor alarm
23.01.2020, 09:37	43853401182,5579	1 (START)	1154	Compressor block 4 - Fan of oil chiller alarm
23.01.2020, 09:47	43853408015	0 (STOP)	1081	Compressor block 1 is not ready
23.01.2020, 09:47	43853408015	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
23.01.2020, 09:47	43853408072,5	0 (STOP)	1082	Compressor block 2 is not ready
23.01.2020, 09:47	43853408072,5	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
23.01.2020, 10:47	43853449446,331	0 (STOP)	1154	Compressor block 4 - Fan of oil chiller alarm
24.01.2020, 09:57	43854415022,7662	1 (START)	1083	Compressor block 3 is not ready
24.01.2020, 09:59	43854416064,4213	0 (STOP)	1083	Compressor block 3 is not ready
24.01.2020, 09:59	43854416076,7477	1 (START)	1142	Compressor block 3 - Compressor 2 motor failure
24.01.2020, 09:59	43854416076,7477	1 (START)	1144	Compressor block 3 - Compressor 2 unacceptable refrigerant pressure
24.01.2020, 09:59	43854416086,8519	0 (STOP)	1142	Compressor block 3 - Compressor 2 motor failure
24.01.2020, 10:08	43854422617,7894	0 (STOP)	1144	Compressor block 3 - Compressor 2 unacceptable refrigerant pressure
25.01.2020, 21:32	43855897444,6759	1 (START)	1001	Fire stop active
25.01.2020, 22:02	43855918500,4745	0 (STOP)	1001	Fire stop active
28.01.2020, 08:13	43858342421,0764	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:47	43858366054,5023	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:47	43858366640,3241	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:50	43858368586,0532	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:50	43858368678,2176	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:52	43858369635,7639	1 (START)	1084	Compressor block 4 is not ready
28.01.2020, 08:52	43858369635,7639	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:52	43858369706,5509	0 (STOP)	1084	Compressor block 4 is not ready
28.01.2020, 08:52	43858369729,456	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:53	43858370354,1667	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:53	43858370390,8218	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:53	43858370644,3981	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:53	43858370667,0949	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:54	43858370852,037	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:54	43858370932,9514	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:56	43858372760,3009	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure

Alarms report 1.2020

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
28.01.2020, 08:56	43858372852,1065	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:57	43858373570,544	1 (START)	1084	Compressor block 4 is not ready
28.01.2020, 08:57	43858373570,544	1 (START)	1110	Compressor block 4 - phase monitor alarm
28.01.2020, 08:57	43858373570,544	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
28.01.2020, 08:59	43858374853,8657	0 (STOP)	1110	Compressor block 4 - phase monitor alarm
28.01.2020, 08:59	43858374866,1227	0 (STOP)	1084	Compressor block 4 is not ready
28.01.2020, 08:59	43858374969,8843	1 (START)	1148	Compressor block 4 - Compressor 2 motor failure
28.01.2020, 09:00	43858375098,2407	0 (STOP)	1148	Compressor block 4 - Compressor 2 motor failure