Alarms report 7.2021

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
02.07.2021, 09:32	44379397732,581	1 (START)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
02.07.2021, 09:47	44379408059,537	0 (STOP)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
02.07.2021, 09:54	44379413071,7245	1 (START)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
02.07.2021, 10:00	44379417258,75	1 (START)	1081	Compressor block 1 is not ready
02.07.2021, 10:00	44379417293,4606	0 (STOP)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
02.07.2021, 10:01	44379417732,5579	0 (STOP)	1081	Compressor block 1 is not ready
06.07.2021, 13:07	44383547045,2778	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
06.07.2021, 16:31	44383688285,2199	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
07.07.2021, 11:41	44384486916,3773	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
08.07.2021, 11:37	44385484645,6366	1 (START)	1130	Compressor block 2 - Compressor 1 motor failure
08.07.2021, 11:38	44385484834,4097	1 (START)	1136	Compressor block 2 - Compressor 3 motor failure
08.07.2021, 12:12	44385508804,294	0 (STOP)	1136	Compressor block 2 - Compressor 3 motor failure
08.07.2021, 12:12	44385508817,0718	0 (STOP)	1130	Compressor block 2 - Compressor 1 motor failure
08.07.2021, 15:16	44385636222,5926	1 (START)	1124	Compressor block 1 - Compressor 2 motor failure
08.07.2021, 16:10	44385674090,8218	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
08.07.2021, 16:10	44385674090,8218	0 (STOP)	1124	Compressor block 1 - Compressor 2 motor failure
08.07.2021, 16:36	44385691944,6412	1 (START)	1130	Compressor block 2 - Compressor 1 motor failure
08.07.2021, 16:36	44385692198,9236	1 (START)	1136	Compressor block 2 - Compressor 3 motor failure
08.07.2021, 16:47	44385699341,8287	1 (START)	1142	Compressor block 3 - Compressor 2 motor failure
08.07.2021, 17:38	44385734775,2083	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
09.07.2021, 07:52	44386328115,8912	0 (STOP)	1136	Compressor block 2 - Compressor 3 motor failure
09.07.2021, 07:52	44386328207,8935	0 (STOP)	1142	Compressor block 3 - Compressor 2 motor failure
09.07.2021, 07:59	44386332636,7014	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
09.07.2021, 07:59	44386332659,9537	0 (STOP)	1130	Compressor block 2 - Compressor 1 motor failure
10.07.2021, 14:56	44387622664,919	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
12.07.2021, 08:23	44389349412,8935	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
13.07.2021, 11:36	44390483697,5694	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
13.07.2021, 15:20	44390639224,7106	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
13.07.2021, 15:20	44390639259,1204	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
15.07.2021, 11:03	44392460539,3866	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
15.07.2021, 11:03	44392460577,5463	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
15.07.2021, 17:09	44392714748,588	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
19.07.2021, 08:43	44396363740,9838	1 (START)	1091	Condenser 1 is not ready
19.07.2021, 08:43	44396363740,9838	1 (START)	1092	Condenser 2 is not ready
19.07.2021, 08:43	44396363740,9838	1 (START)	1093	Condenser 3 is not ready
19.07.2021, 08:43	44396363752,2917	0 (STOP)	1091	Condenser 1 is not ready
19.07.2021, 08:43	44396363752,2917	0 (STOP)	1092	Condenser 2 is not ready
19.07.2021, 08:43	44396363752,2917	0 (STOP)	1093	Condenser 3 is not ready
26.07.2021, 12:46	44403531969,7222	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
27.07.2021, 19:14	44404801740,2546	1 (START)	1010	0.01 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801740,2546	1 (START)	1030	0.03 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801740,2546	1 (START)	1020	0.02 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801740,2546	1 (START)	1040	0.04 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801740,2546	1 (START)	1050	0.05 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801740,2546	1 (START)	1070	0.07 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801740,2546	1 (START)	1091	Condenser 1 is not ready
27.07.2021, 19:14	44404801740,2546	1 (START)	1092	Condenser 2 is not ready
27.07.2021, 19:14	44404801740,2546	1 (START)	1093	Condenser 3 is not ready
27.07.2021, 19:14	44404801740,2546	1 (START)	1081	Compressor block 1 is not ready
27.07.2021, 19:14	44404801740,2546	1 (START)	1082	Compressor block 2 is not ready
27.07.2021, 19:14	44404801740,2546	1 (START)	1083	Compressor block 3 is not ready

Alarms report 7.2021

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
27.07.2021, 19:14	44404801740,2546	1 (START)	1084	Compressor block 4 is not ready
27.07.2021, 19:14	44404801740,2546	1 (START)	1107	Compressor block 1 - phase monitor alarm
27.07.2021, 19:14	44404801740,2546	1 (START)	1108	Compressor block 2 - phase monitor alarm
27.07.2021, 19:14	44404801740,2546	1 (START)	1109	Compressor block 3 - phase monitor alarm
27.07.2021, 19:14	44404801740,2546	1 (START)	1110	Compressor block 4 - phase monitor alarm
27.07.2021, 19:14	44404801740,2546	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
27.07.2021, 19:14	44404801740,2546	1 (START)	1100	Main power supply interrupted (U = 0 V)
27.07.2021, 19:14	44404801751,7708	0 (STOP)	1010	0.01 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801751,7708	0 (STOP)	1030	0.03 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801751,7708	0 (STOP)	1020	0.02 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801751,7708	0 (STOP)	1040	0.04 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801751,7708	0 (STOP)	1070	0.07 - Evaporator - electrical power is switched off
27.07.2021, 19:14	44404801751,7708	0 (STOP)	1100	Main power supply interrupted (U = 0 V)
27.07.2021, 19:14	44404801798,7384	0 (STOP)	1091	Condenser 1 is not ready
27.07.2021, 19:14	44404801798,7384	0 (STOP)	1092	Condenser 2 is not ready
27.07.2021, 19:14	44404801798,7384	0 (STOP)	1093	Condenser 3 is not ready
27.07.2021, 19:15	44404802237,0949	0 (STOP)	1050	0.05 - Evaporator - electrical power is switched off
27.07.2021, 19:44	44404822391,875	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
27.07.2021, 19:44	44404822469,0741	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
27.07.2021, 19:44	44404822500,2546	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
27.07.2021, 19:44	44404822818,2986	0 (STOP)	1082	Compressor block 2 is not ready
27.07.2021, 19:45	44404823072,7315	0 (STOP)	1081	Compressor block 1 is not ready
27.07.2021, 19:45	44404823244,294	0 (STOP)	1083	Compressor block 3 is not ready
27.07.2021, 19:53	44404829021,9792	0 (STOP)	1084	Compressor block 4 is not ready
27.07.2021, 19:53	44404829021,9792	0 (STOP)	1110	Compressor block 4 - phase monitor alarm
28.07.2021, 11:10	44405465462,0486	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
28.07.2021, 14:03	44405585908,044	1 (START)	1136	Compressor block 2 - Compressor 3 motor failure