Alarms report 8.2021

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
02.08.2021, 09:12	44410383936,4236	0 (STOP)	1136	Compressor block 2 - Compressor 3 motor failure
02.08.2021, 09:16	44410386654,6412	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
02.08.2021, 09:16	44410386689,6644	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
02.08.2021, 09:17	44410386816,7245	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
08.08.2021, 23:01	44416959055,7407	1 (START)	1010	0.01 - Evaporator - electrical power is switched off
08.08.2021, 23:01	44416959055,7407	1 (START)	1050	0.05 - Evaporator - electrical power is switched off
08.08.2021, 23:01	44416959055,7407	1 (START)	1091	Condenser 1 is not ready
08.08.2021, 23:01	44416959055,7407	1 (START)	1092	Condenser 2 is not ready
08.08.2021, 23:01	44416959055,7407	1 (START)	1093	Condenser 3 is not ready
08.08.2021, 23:01	44416959055,7407	1 (START)	1081	Compressor block 1 is not ready
08.08.2021, 23:01	44416959055,7407	1 (START)	1082	Compressor block 2 is not ready
08.08.2021, 23:01	44416959055,7407	1 (START)	1083	Compressor block 3 is not ready
08.08.2021, 23:01	44416959055,7407	1 (START)	1107	Compressor block 1 - phase monitor alarm
08.08.2021, 23:01	44416959055,7407	1 (START)	1108	Compressor block 2 - phase monitor alarm
08.08.2021, 23:01	44416959055,7407	1 (START)	1109	Compressor block 3 - phase monitor alarm
08.08.2021, 23:01	44416959065,9375	0 (STOP)	1010	0.01 - Evaporator - electrical power is switched off
08.08.2021, 23:01	44416959065,9375	0 (STOP)	1050	0.05 - Evaporator - electrical power is switched off
08.08.2021, 23:01	44416959065,9375	0 (STOP)	1091	Condenser 1 is not ready
08.08.2021, 23:01	44416959065,9375	0 (STOP)	1092	Condenser 2 is not ready
08.08.2021, 23:01	44416959065,9375	0 (STOP)	1093	Condenser 3 is not ready
08.08.2021, 23:59	44416999978,5764	0 (STOP)	1082	Compressor block 2 is not ready
08.08.2021, 23:59	44416999978,5764	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
09.08.2021, 00:00	44417000048,8079	0 (STOP)	1083	Compressor block 3 is not ready
09.08.2021, 00:00	44417000048,8079	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
09.08.2021, 00:00	44417000084,2361	0 (STOP)	1081	Compressor block 1 is not ready
09.08.2021, 00:00	44417000084,2361	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
11.08.2021, 13:49	44419575826,3194	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
13.08.2021, 10:10	44421424029,5023	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
14.08.2021, 15:11	44422632734,2014	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
17.08.2021, 00:50	44425034979,7685	1 (START)	1091	Condenser 1 is not ready
17.08.2021, 00:50	44425034979,7685	1 (START)	1092	Condenser 2 is not ready
17.08.2021, 00:50	44425034979,7685	1 (START)	1093	Condenser 3 is not ready
17.08.2021, 00:50	44425035000,2083	0 (STOP)	1091	Condenser 1 is not ready
17.08.2021, 00:50	44425035000,2083	0 (STOP)	1092	Condenser 2 is not ready
17.08.2021, 00:50	44425035000,2083	0 (STOP)	1093	Condenser 3 is not ready
17.08.2021, 00:50	44425035035,6829	1 (START)	1154	Compressor block 4 - Fan of oil chiller alarm
17.08.2021, 01:37	44425067536,5162	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 08:03	44425335864,4792	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
17.08.2021, 08:13	44425342691,5046	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 08:13	44425342815,7755	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 08:14	44425343619,8843	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 08:15	44425343839,7685	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 08:19	44425346681,1921	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 08:19	44425346766,3079	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 08:20	44425347494,0394	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 08:20	44425347664,6296	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:21	44425390049,4907	0 (STOP)	1154	Compressor block 4 - Fan of oil chiller alarm
17.08.2021, 09:21	44425390210,8681	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:21	44425390268,9352	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:22	44425390569,2708	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:22	44425390662,9514	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure

Alarms report 8.2021

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
17.08.2021, 09:24	44425392340,7292	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:25	44425392998,75	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:28	44425394747,1181	1 (START)	1084	Compressor block 4 is not ready
17.08.2021, 09:28	44425394759,456	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:28	44425394828,7731	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:28	44425394849,1088	0 (STOP)	1084	Compressor block 4 is not ready
17.08.2021, 09:30	44425395983,7847	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:34	44425398676,8056	1 (START)	1084	Compressor block 4 is not ready
17.08.2021, 09:35	44425399393,4375	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:35	44425399670,9375	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 09:35	44425399887,6042	1 (START)	1110	Compressor block 4 - phase monitor alarm
17.08.2021, 09:36	44425400359,0625	0 (STOP)	1084	Compressor block 4 is not ready
17.08.2021, 09:36	44425400359,0625	0 (STOP)	1110	Compressor block 4 - phase monitor alarm
17.08.2021, 09:36	44425400627,2222	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:40	44425486549,1782	1 (START)	1084	Compressor block 4 is not ready
17.08.2021, 11:40	44425486549,1782	1 (START)	1110	Compressor block 4 - phase monitor alarm
17.08.2021, 11:40	44425486549,1782	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:41	44425487204,7222	0 (STOP)	1084	Compressor block 4 is not ready
17.08.2021, 11:41	44425487204,7222	0 (STOP)	1110	Compressor block 4 - phase monitor alarm
17.08.2021, 11:41	44425487227,7431	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:43	44425488264,0278	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:43	44425488293,7384	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:43	44425488682,3032	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:43	44425488706,1343	1 (START)	1084	Compressor block 4 is not ready
17.08.2021, 11:43	44425488790,787	0 (STOP)	1084	Compressor block 4 is not ready
17.08.2021, 11:43	44425488823,2986	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:49	44425492988,8079	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:50	44425493250,706	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:53	44425495664,8843	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:56	44425497404,8148	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:56	44425497743,7153	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:56	44425497861,9097	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 11:59	44425499374,0625	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:00	44425500043,912	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:00	44425500140,4514	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:00	44425500272,3264	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:01	44425501105,6366	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:02	44425501968,7616	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:03	44425502179,4213	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:03	44425502524,5255	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:04	44425502815,2083	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:11	44425508000,6829	1 (START)	1148	Compressor block 4 - Compressor 2 motor failure
17.08.2021, 12:11	44425508000,6829	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:11	44425508011,9097	0 (STOP)	1148	Compressor block 4 - Compressor 2 motor failure
17.08.2021, 12:16	44425511561,3079	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:16	44425511617,7546	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:17	44425512347,4537	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:18	44425513096,9097	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:19	44425513249,9884	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:19	44425513708,9005	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:20	44425514169,7685	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure

Alarms report 8.2021

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
17.08.2021, 12:20	44425514200,7292	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:33	44425523063,831	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:34	44425523949,3634	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:37	44425526094,6065	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:39	44425527297,5579	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:40	44425528349,3287	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:43	44425530257,1412	1 (START)	1148	Compressor block 4 - Compressor 2 motor failure
17.08.2021, 12:43	44425530257,1412	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:43	44425530268,3565	0 (STOP)	1148	Compressor block 4 - Compressor 2 motor failure
17.08.2021, 12:43	44425530406,6667	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:47	44425532922,8472	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:47	44425532935,2199	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:48	44425533907,3727	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:57	44425539779,6875	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 12:57	44425539907,2106	1 (START)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 13:07	44425546929,0394	0 (STOP)	1150	Compressor block 4 - Compressor 2 unacceptable refrigerant pressure
17.08.2021, 13:09	44425548583,4954	1 (START)	1084	Compressor block 4 is not ready
17.08.2021, 13:10	44425548896,3194	1 (START)	1148	Compressor block 4 - Compressor 2 motor failure
17.08.2021, 13:10	44425548907,6157	0 (STOP)	1148	Compressor block 4 - Compressor 2 motor failure
17.08.2021, 13:11	44425549531,6782	0 (STOP)	1084	Compressor block 4 is not ready
17.08.2021, 13:11	44425549543,2986	1 (START)	1145	Compressor block 4 - Compressor 1 motor failure
17.08.2021, 13:11	44425549554,8148	0 (STOP)	1145	Compressor block 4 - Compressor 1 motor failure
17.08.2021, 13:20	44425555836,5741	1 (START)	1084	Compressor block 4 is not ready
17.08.2021, 13:20	44425555894,4444	0 (STOP)	1084	Compressor block 4 is not ready