Alarms report 3.2022

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
01.03.2022, 15:44	44621655859,1551	1 (START)	1050	0.05 - Evaporator - electrical power is switched off
01.03.2022, 15:44	44621655871,0764	1 (START)	1084	Compressor block 4 is not ready
01.03.2022, 15:44	44621655871,0764	1 (START)	1110	Compressor block 4 - phase monitor alarm
01.03.2022, 15:46	44621656993,8079	0 (STOP)	1050	0.05 - Evaporator - electrical power is switched off
01.03.2022, 15:46	44621657050,4051	0 (STOP)	1084	Compressor block 4 is not ready
01.03.2022, 15:46	44621657050,4051	0 (STOP)	1110	Compressor block 4 - phase monitor alarm
01.03.2022, 15:46	44621657062,8588	1 (START)	1146	Compressor block 4 - Compressor 1 low oil flow alarm
01.03.2022, 15:46	44621657062,8588	1 (START)	1149	Compressor block 4 - Compressor 2 low oil flow alarm
01.03.2022, 15:47	44621657756,2384	1 (START)	1084	Compressor block 4 is not ready
01.03.2022, 15:47	44621657756,2384	0 (STOP)	1146	Compressor block 4 - Compressor 1 low oil flow alarm
01.03.2022, 15:47	44621657756,2384	0 (STOP)	1149	Compressor block 4 - Compressor 2 low oil flow alarm
01.03.2022, 15:47	44621657790,9954	0 (STOP)	1084	Compressor block 4 is not ready
01.03.2022, 15:47	44621657801,9444	1 (START)	1148	Compressor block 4 - Compressor 2 motor failure
01.03.2022, 15:47	44621657814,0046	0 (STOP)	1148	Compressor block 4 - Compressor 2 motor failure
04.03.2022, 09:41	44624404047,5347	1 (START)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 09:42	44624404243,7847	1 (START)	1081	Compressor block 1 is not ready
04.03.2022, 09:45	44624406673,6806	0 (STOP)	1081	Compressor block 1 is not ready
04.03.2022, 09:45	44624406673,6806	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 09:47	44624408290,7986	1 (START)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 09:48	44624408487,5463	1 (START)	1081	Compressor block 1 is not ready
04.03.2022, 09:52	44624411604,0856	0 (STOP)	1081	Compressor block 1 is not ready
04.03.2022, 09:52	44624411604,0856	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 09:52	44624411778,206	1 (START)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 09:53	44624411986,1111	1 (START)	1081	Compressor block 1 is not ready
04.03.2022, 09:55	44624413209,8264	0 (STOP)	1081	Compressor block 1 is not ready
04.03.2022, 09:55	44624413209,8264	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 09:55	44624413303,1713	1 (START)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 09:55	44624413499,2477	1 (START)	1081	Compressor block 1 is not ready
04.03.2022, 10:05	44624420421,7245	0 (STOP)	1081	Compressor block 1 is not ready
04.03.2022, 10:05	44624420421,7245	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:05	44624420583,3565	1 (START)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:05	44624420790,9375	1 (START)	1081	Compressor block 1 is not ready
04.03.2022, 10:14	44624426452,8009	1 (START)	1091	Condenser 1 is not ready
04.03.2022, 10:14	44624426452,8009	1 (START)	1107	Compressor block 1 - phase monitor alarm
04.03.2022, 10:14	44624426452,8009	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:16	44624428210,8218	0 (STOP)	1091	Condenser 1 is not ready
04.03.2022, 10:17	44624428577,1065	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
04.03.2022, 10:17	44624428603,6458	1 (START)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:28	44624436233,8079	0 (STOP)	1081	Compressor block 1 is not ready
04.03.2022, 10:28	44624436233,8079	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:29	44624437122,7662	1 (START)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:29	44624437318,8773	1 (START)	1081	Compressor block 1 is not ready
04.03.2022, 10:30	44624437585,8565	1 (START)	1001	Fire stop active
04.03.2022, 10:30	44624437597,338	0 (STOP)	1081	Compressor block 1 is not ready
04.03.2022, 10:30	44624437597,338	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:30	44624437677,5694	1 (START)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:30	44624437885,8333	1 (START)	1081	Compressor block 1 is not ready
04.03.2022, 10:32	44624439491,8519	0 (STOP)	1001	Fire stop active
04.03.2022, 10:45	44624448229,0394	0 (STOP)	1081	Compressor block 1 is not ready
04.03.2022, 10:45	44624448229,0394	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:45	44624448299,0972	1 (START)	1112	Compressor block 1 - oil low level alarm

Alarms report 3.2022

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
04.03.2022, 10:45	44624448506,2963	1 (START)	1081	Compressor block 1 is not ready
04.03.2022, 10:47	44624449316,3773	0 (STOP)	1081	Compressor block 1 is not ready
04.03.2022, 10:47	44624449316,3773	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:48	44624450229,5833	1 (START)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 10:48	44624450426,1921	1 (START)	1081	Compressor block 1 is not ready
04.03.2022, 10:52	44624452852,8125	0 (STOP)	1081	Compressor block 1 is not ready
04.03.2022, 10:52	44624452852,8125	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 11:11	44624466063,1019	1 (START)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 11:11	44624466259,7801	1 (START)	1081	Compressor block 1 is not ready
04.03.2022, 11:11	44624466546,5393	0 (STOP)	1081	Compressor block 1 is not ready
04.03.2022, 11:11	44624466546,5393	0 (STOP)	1112	Compressor block 1 - oil low level alarm
04.03.2022, 11:27	44624477734,6991	1 (START)	1001	Fire stop active
04.03.2022, 11:29	44624478591,4699	0 (STOP)	1001	Fire stop active
04.03.2022, 14:53	44624620183,3681	1 (START)	1083	Compressor block 3 is not ready
09.03.2022, 08:34	44629357363,5185	1 (START)	1109	Compressor block 3 - phase monitor alarm
21.03.2022, 17:02	44641710263,2639	1 (START)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
21.03.2022, 17:04	44641711142,7431	1 (START)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
21.03.2022, 17:06	44641712958,4143	1 (START)	1082	Compressor block 2 is not ready
21.03.2022, 17:06	44641712981,5741	1 (START)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
22.03.2022, 07:46	44642323644,5023	0 (STOP)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
22.03.2022, 07:46	44642323702,4306	1 (START)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
22.03.2022, 07:46	44642323725,544	0 (STOP)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
22.03.2022, 07:46	44642323795	1 (START)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
22.03.2022, 07:46	44642323979,5486	0 (STOP)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
22.03.2022, 07:46	44642324014,2708	0 (STOP)	1082	Compressor block 2 is not ready
22.03.2022, 07:48	44642325471,7477	0 (STOP)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
22.03.2022, 07:48	44642325483,3333	0 (STOP)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
22.03.2022, 07:54	44642329580,2894	1 (START)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
22.03.2022, 07:54	44642329730,7986	1 (START)	1082	Compressor block 2 is not ready
22.03.2022, 07:55	44642330424,8843	0 (STOP)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
22.03.2022, 07:55	44642330436,4931	0 (STOP)	1082	Compressor block 2 is not ready
22.03.2022, 08:02	44642334729,7917	1 (START)	1082	Compressor block 2 is not ready
22.03.2022, 08:03	44642335412,5	0 (STOP)	1082	Compressor block 2 is not ready
22.03.2022, 08:03	44642336083,5648	1 (START)	1082	Compressor block 2 is not ready
22.03.2022, 08:03	44642336095,162	1 (START)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
22.03.2022, 08:04	44642336118,287	0 (STOP)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
22.03.2022, 11:00	44642458348,1134	0 (STOP)	1082	Compressor block 2 is not ready
22.03.2022, 11:01	44642459458,7384	1 (START)	1082	Compressor block 2 is not ready
22.03.2022, 11:02	44642459910,1736	1 (START)	1130	Compressor block 2 - Compressor 1 motor failure
22.03.2022, 11:02	44642459910,1736	1 (START)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
22.03.2022, 11:02	44642459921,7593	0 (STOP)	1130	Compressor block 2 - Compressor 1 motor failure
22.03.2022, 11:02	44642459968,0787	0 (STOP)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
22.03.2022, 11:04	44642461367,2338	0 (STOP)	1082	Compressor block 2 is not ready
22.03.2022, 11:05	44642462188,3796	1 (START)	1082	Compressor block 2 is not ready
22.03.2022, 11:07	44642463275,6366	0 (STOP)	1082	Compressor block 2 is not ready
22.03.2022, 11:07	44642463437,7199	1 (START)	1082	Compressor block 2 is not ready
22.03.2022, 13:33	44642564633,9468	0 (STOP)	1082	Compressor block 2 is not ready
22.03.2022, 13:35	44642566600,3009	1 (START)	1082	Compressor block 2 is not ready
22.03.2022, 14:06	44642588168,4259	0 (STOP)	1082	Compressor block 2 is not ready
22.03.2022, 14:08	44642589325,9143	1 (START)	1082	Compressor block 2 is not ready
22.03.2022, 15:23	44642641005,4745	0 (STOP)	1082	Compressor block 2 is not ready

Alarms report 3.2022

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
22.03.2022, 15:23	44642641017,0255	1 (START)	1130	Compressor block 2 - Compressor 1 motor failure
22.03.2022, 15:23	44642641028,6227	0 (STOP)	1130	Compressor block 2 - Compressor 1 motor failure
23.03.2022, 12:37	44643526096,7014	1 (START)	1141	Compressor block 3 - Compressor 1 unacceptable refrigerant pressure
23.03.2022, 12:38	44643526478,5648	0 (STOP)	1141	Compressor block 3 - Compressor 1 unacceptable refrigerant pressure
23.03.2022, 12:38	44643526500,9144	1 (START)	1139	Compressor block 3 - Compressor 1 motor failure
23.03.2022, 12:38	44643526515,5556	0 (STOP)	1139	Compressor block 3 - Compressor 1 motor failure
23.03.2022, 12:39	44643527679,2014	1 (START)	1141	Compressor block 3 - Compressor 1 unacceptable refrigerant pressure
23.03.2022, 12:48	44643533589,5139	0 (STOP)	1141	Compressor block 3 - Compressor 1 unacceptable refrigerant pressure
23.03.2022, 13:58	44643582036,1343	1 (START)	1107	Compressor block 1 - phase monitor alarm
23.03.2022, 13:58	44643582036,1343	1 (START)	1108	Compressor block 2 - phase monitor alarm
23.03.2022, 13:58	44643582036,1343	1 (START)	1109	Compressor block 3 - phase monitor alarm
23.03.2022, 14:09	44643590175,1505	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
23.03.2022, 14:09	44643590175,1505	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
23.03.2022, 14:09	44643590175,1505	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
23.03.2022, 14:59	44643624869,0162	1 (START)	1107	Compressor block 1 - phase monitor alarm
23.03.2022, 14:59	44643624869,0162	1 (START)	1108	Compressor block 2 - phase monitor alarm
23.03.2022, 14:59	44643624869,0162	1 (START)	1109	Compressor block 3 - phase monitor alarm
23.03.2022, 15:18	44643638126,4352	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
23.03.2022, 15:18	44643638126,4352	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
23.03.2022, 15:18	44643638126,4352	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
23.03.2022, 15:23	44643641063,0787	1 (START)	1001	Fire stop active
23.03.2022, 15:25	44643642416,8287	0 (STOP)	1001	Fire stop active
24.03.2022, 10:37	44644443043,4144	1 (START)	1083	Compressor block 3 is not ready
24.03.2022, 10:46	44644449063,044	1 (START)	1114	Compressor block 3 - oil low level alarm
24.03.2022, 10:51	44644452090,3472	1 (START)	1109	Compressor block 3 - phase monitor alarm
24.03.2022, 10:51	44644452090,3472	0 (STOP)	1114	Compressor block 3 - oil low level alarm
24.03.2022, 12:33	44644523098,1597	1 (START)	1001	Fire stop active
24.03.2022, 12:37	44644525815,8449	0 (STOP)	1001	Fire stop active
24.03.2022, 12:41	44644528649,3519	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
24.03.2022, 12:41	44644529008,7037	0 (STOP)	1083	Compressor block 3 is not ready
24.03.2022, 12:41	44644529031,4468	1 (START)	1139	Compressor block 3 - Compressor 1 motor failure
24.03.2022, 12:41	44644529043,4954	0 (STOP)	1139	Compressor block 3 - Compressor 1 motor failure
24.03.2022, 13:25	44644559306,4583	1 (START)	1010	0.01 - Evaporator - electrical power is switched off
24.03.2022, 13:27	44644560683,3333	0 (STOP)	1010	0.01 - Evaporator - electrical power is switched off
25.03.2022, 09:30	44645396218,5069	1 (START)	1082	Compressor block 2 is not ready
25.03.2022, 09:30	44645396311,9097	1 (START)	1108	Compressor block 2 - phase monitor alarm
25.03.2022, 09:40	44645402823,75	0 (STOP)	1082	Compressor block 2 is not ready
25.03.2022, 09:40	44645402823,75	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
25.03.2022, 10:03	44645419266,088	1 (START)	1082	Compressor block 2 is not ready
25.03.2022, 10:03	44645419277,1065	1 (START)	1092	Condenser 2 is not ready
25.03.2022, 10:03	44645419299,5602	1 (START)	1113	Compressor block 2 - oil low level alarm
25.03.2022, 10:05	44645420189,7454	0 (STOP)	1092	Condenser 2 is not ready
25.03.2022, 10:05	44645420189,7454	0 (STOP)	1082	Compressor block 2 is not ready
25.03.2022, 10:05	44645420213,1945	0 (STOP)	1113	Compressor block 2 - oil low level alarm
25.03.2022, 10:10	44645424143,6806	1 (START)	1141	Compressor block 3 - Compressor 1 unacceptable refrigerant pressure
25.03.2022, 10:11	44645424455,1736	0 (STOP)	1141	Compressor block 3 - Compressor 1 unacceptable refrigerant pressure
25.03.2022, 10:11	44645424594,0046	1 (START)	1141	Compressor block 3 - Compressor 1 unacceptable refrigerant pressure
25.03.2022, 10:13	44645425851,5046	1 (START)	1083	Compressor block 3 is not ready
25.03.2022, 10:13	44645425874,8264	1 (START)	1144	Compressor block 3 - Compressor 2 unacceptable refrigerant pressure
25.03.2022, 10:14	44645426429,0972	0 (STOP)	1141	Compressor block 3 - Compressor 1 unacceptable refrigerant pressure
25.03.2022, 10:14	44645426441,7014	0 (STOP)	1083	Compressor block 3 is not ready

Alarms report 3.2022

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
25.03.2022, 10:14	44645426452,1065	0 (STOP)	1144	Compressor block 3 - Compressor 2 unacceptable refrigerant pressure
25.03.2022, 10:41	44645445585,0347	1 (START)	1092	Condenser 2 is not ready
25.03.2022, 10:41	44645445585,0347	1 (START)	1082	Compressor block 2 is not ready
25.03.2022, 10:41	44645445607,8125	1 (START)	1113	Compressor block 2 - oil low level alarm
25.03.2022, 10:43	44645446832,7546	0 (STOP)	1092	Condenser 2 is not ready
25.03.2022, 10:43	44645446832,7546	0 (STOP)	1082	Compressor block 2 is not ready
25.03.2022, 10:43	44645446844,4676	0 (STOP)	1113	Compressor block 2 - oil low level alarm
25.03.2022, 12:54	44645538136,4236	1 (START)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
25.03.2022, 13:02	44645543430,6944	1 (START)	1081	Compressor block 1 is not ready
25.03.2022, 13:02	44645543464,9769	1 (START)	1107	Compressor block 1 - phase monitor alarm
25.03.2022, 13:02	44645543476,0301	1 (START)	1091	Condenser 1 is not ready
25.03.2022, 13:02	44645543708,5069	0 (STOP)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
25.03.2022, 13:03	44645544065,7986	1 (START)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
25.03.2022, 13:04	44645544920,6713	0 (STOP)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
25.03.2022, 13:04	44645544954,9769	1 (START)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
25.03.2022, 13:04	44645545024,6643	1 (START)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
25.03.2022, 13:05	44645545141,0301	0 (STOP)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
25.03.2022, 13:05	44645545602,6505	0 (STOP)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
25.03.2022, 13:07	44645546586,0185	0 (STOP)	1091	Condenser 1 is not ready
25.03.2022, 13:07	44645547002,882	0 (STOP)	1081	Compressor block 1 is not ready
25.03.2022, 13:07	44645547002,882	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
25.03.2022, 13:37	44645567361,8634	1 (START)	1123	Compressor block 1 - Compressor 1 unacceptable refrigerant pressure
25.03.2022, 13:37	44645567916,9676	0 (STOP)	1123	Compressor block 1 - Compressor 1 unacceptable refrigerant pressure
25.03.2022, 13:38	44645568411,9329	1 (START)	1126	Compressor block 1 - Compressor 2 unacceptable refrigerant pressure
25.03.2022, 13:39	44645569001,0532	0 (STOP)	1126	Compressor block 1 - Compressor 2 unacceptable refrigerant pressure
25.03.2022, 13:39	44645569360,3588	1 (START)	1129	Compressor block 1 - Compressor 3 unacceptable refrigerant pressure
25.03.2022, 13:40	44645569949,4097	0 (STOP)	1129	Compressor block 1 - Compressor 3 unacceptable refrigerant pressure
25.03.2022, 13:42	44645571152,4653	1 (START)	1001	Fire stop active
25.03.2022, 13:43	44645571625,7639	0 (STOP)	1001	Fire stop active
25.03.2022, 13:43	44645571661,3542	1 (START)	1001	Fire stop active
25.03.2022, 13:43	44645572089,4676	0 (STOP)	1001	Fire stop active
28.03.2022, 13:01	44648542880,7755	1 (START)	1010	0.01 - Evaporator - electrical power is switched off
28.03.2022, 13:02	44648543424,1204	1 (START)	1020	0.02 - Evaporator - electrical power is switched off
28.03.2022, 13:02	44648543679,0972	1 (START)	1030	0.03 - Evaporator - electrical power is switched off
28.03.2022, 13:03	44648543852,6968	1 (START)	1070	0.07 - Evaporator - electrical power is switched off
28.03.2022, 13:03	44648543898,7616	1 (START)	1040	0.04 - Evaporator - electrical power is switched off
28.03.2022, 13:03	44648544360,1736	0 (STOP)	1070	0.07 - Evaporator - electrical power is switched off
28.03.2022, 13:04	44648544521,956	1 (START)	1070	0.07 - Evaporator - electrical power is switched off
28.03.2022, 13:08	44648547814,6412	0 (STOP)	1020	0.02 - Evaporator - electrical power is switched off
28.03.2022, 13:08	44648547873,3681	0 (STOP)	1030	0.03 - Evaporator - electrical power is switched off
28.03.2022, 13:09	44648547918,6111	0 (STOP)	1070	0.07 - Evaporator - electrical power is switched off
28.03.2022, 13:09	44648547965,162	0 (STOP)	1040	0.04 - Evaporator - electrical power is switched off
28.03.2022, 13:09	44648548162,1875	0 (STOP)	1010	0.01 - Evaporator - electrical power is switched off
28.03.2022, 13:14	44648551477,9514	1 (START)	1081	Compressor block 1 is not ready
28.03.2022, 13:14	44648551477,9514	1 (START)	1107	Compressor block 1 - phase monitor alarm
28.03.2022, 13:22	44648557419,7454	0 (STOP)	1081	Compressor block 1 is not ready
28.03.2022, 13:22	44648557419,7454	0 (STOP)	1107	Compressor block 1 - phase monitor alarm
28.03.2022, 13:26	44648559741,7708	1 (START)	1082	Compressor block 2 is not ready
28.03.2022, 13:26	44648559741,7708	1 (START)	1108	Compressor block 2 - phase monitor alarm
28.03.2022, 13:28	44648561581,0648	1 (START)	1083	Compressor block 3 is not ready
28.03.2022, 13:28	44648561581,0648	1 (START)	1109	Compressor block 3 - phase monitor alarm

Alarms report 3.2022

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
28.03.2022, 13:28	44648561777,6273	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
28.03.2022, 13:28	44648561788,7269	0 (STOP)	1082	Compressor block 2 is not ready
28.03.2022, 13:30	44648563129,6412	0 (STOP)	1083	Compressor block 3 is not ready
28.03.2022, 13:30	44648563129,6412	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
28.03.2022, 13:44	44648572875,8333	1 (START)	1083	Compressor block 3 is not ready
28.03.2022, 13:44	44648572875,8333	1 (START)	1109	Compressor block 3 - phase monitor alarm
28.03.2022, 13:47	44648574923,2176	1 (START)	1137	Compressor block 2 - Compressor 3 low oil flow alarm
28.03.2022, 13:49	44648576218,044	0 (STOP)	1137	Compressor block 2 - Compressor 3 low oil flow alarm
28.03.2022, 13:50	44648576392,2454	0 (STOP)	1083	Compressor block 3 is not ready
28.03.2022, 13:50	44648576392,2454	0 (STOP)	1109	Compressor block 3 - phase monitor alarm
28.03.2022, 13:50	44648577061,7014	1 (START)	1131	Compressor block 2 - Compressor 1 low oil flow alarm
28.03.2022, 13:52	44648577825,1273	0 (STOP)	1131	Compressor block 2 - Compressor 1 low oil flow alarm
28.03.2022, 13:52	44648577883,0556	1 (START)	1134	Compressor block 2 - Compressor 2 low oil flow alarm
28.03.2022, 13:53	44648578981,3542	0 (STOP)	1134	Compressor block 2 - Compressor 2 low oil flow alarm
28.03.2022, 13:54	44648579246,5162	1 (START)	1128	Compressor block 1 - Compressor 3 low oil flow alarm
28.03.2022, 13:56	44648580727,0023	1 (START)	1122	Compressor block 1 - Compressor 1 low oil flow alarm
28.03.2022, 13:59	44648583049,0625	0 (STOP)	1122	Compressor block 1 - Compressor 1 low oil flow alarm
28.03.2022, 13:59	44648583060,5208	0 (STOP)	1128	Compressor block 1 - Compressor 3 low oil flow alarm
28.03.2022, 13:59	44648583072,0486	1 (START)	1122	Compressor block 1 - Compressor 1 low oil flow alarm
28.03.2022, 13:59	44648583083,5764	0 (STOP)	1122	Compressor block 1 - Compressor 1 low oil flow alarm
28.03.2022, 13:59	44648583118,3218	1 (START)	1121	Compressor block 1 - Compressor 1 motor failure
28.03.2022, 13:59	44648583129,8727	0 (STOP)	1121	Compressor block 1 - Compressor 1 motor failure
28.03.2022, 14:00	44648583361,6898	1 (START)	1125	Compressor block 1 - Compressor 2 low oil flow alarm
28.03.2022, 14:01	44648584065,5671	0 (STOP)	1125	Compressor block 1 - Compressor 2 low oil flow alarm
28.03.2022, 14:04	44648586584,9421	1 (START)	1141	Compressor block 3 - Compressor 1 unacceptable refrigerant pressure
28.03.2022, 14:05	44648586804,8843	1 (START)	1083	Compressor block 3 is not ready
28.03.2022, 14:05	44648586816,713	1 (START)	1144	Compressor block 3 - Compressor 2 unacceptable refrigerant pressure
28.03.2022, 14:05	44648587405,6829	1 (START)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
28.03.2022, 14:06	44648587718,4259	0 (STOP)	1083	Compressor block 3 is not ready
28.03.2022, 14:06	44648587718,4259	0 (STOP)	1144	Compressor block 3 - Compressor 2 unacceptable refrigerant pressure
28.03.2022, 14:06	44648587730,9606	0 (STOP)	1141	Compressor block 3 - Compressor 1 unacceptable refrigerant pressure
28.03.2022, 14:06	44648587846,1343	1 (START)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
28.03.2022, 14:06	44648587880,7986	1 (START)	1082	Compressor block 2 is not ready
28.03.2022, 14:06	44648587903,2755	1 (START)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
28.03.2022, 14:08	44648589557,7662	0 (STOP)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
28.03.2022, 14:08	44648589557,7662	0 (STOP)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
28.03.2022, 14:08	44648589557,7662	0 (STOP)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
28.03.2022, 14:09	44648589580,3241	1 (START)	1113	Compressor block 2 - oil low level alarm
28.03.2022, 14:09	44648589674,7222	0 (STOP)	1113	Compressor block 2 - oil low level alarm
28.03.2022, 14:09	44648589696,0648	1 (START)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
28.03.2022, 14:09	44648589696,0648	1 (START)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
28.03.2022, 14:09	44648589696,0648	1 (START)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
28.03.2022, 14:09	44648589950,8912	0 (STOP)	1132	Compressor block 2 - Compressor 1 unacceptable refrigerant pressure
28.03.2022, 14:09	44648589962,5116	0 (STOP)	1082	Compressor block 2 is not ready
28.03.2022, 14:09	44648589973,9352	0 (STOP)	1135	Compressor block 2 - Compressor 2 unacceptable refrigerant pressure
28.03.2022, 14:09	44648589997,4769	0 (STOP)	1138	Compressor block 2 - Compressor 3 unacceptable refrigerant pressure
28.03.2022, 14:10	44648590530,2315	1 (START)	1123	Compressor block 1 - Compressor 1 unacceptable refrigerant pressure
28.03.2022, 14:10	44648590657,9051	1 (START)	1129	Compressor block 1 - Compressor 3 unacceptable refrigerant pressure
28.03.2022, 14:10	44648590796,5972	1 (START)	1081	Compressor block 1 is not ready
28.03.2022, 14:10	44648590806,8403	1 (START)	1126	Compressor block 1 - Compressor 2 unacceptable refrigerant pressure
28.03.2022, 14:12	44648591975,8796	1 (START)	1113	Compressor block 2 - oil low level alarm

Alarms report 3.2022

Date, Time	Time_ms	StateAfter	MsgNumber	MsgText
28.03.2022, 14:12	44648592173,2986	1 (START)	1082	Compressor block 2 is not ready
28.03.2022, 14:13	44648592633,7269	0 (STOP)	1123	Compressor block 1 - Compressor 1 unacceptable refrigerant pressure
28.03.2022, 14:13	44648592633,7269	0 (STOP)	1126	Compressor block 1 - Compressor 2 unacceptable refrigerant pressure
28.03.2022, 14:13	44648592633,7269	0 (STOP)	1129	Compressor block 1 - Compressor 3 unacceptable refrigerant pressure
28.03.2022, 14:13	44648592656,7014	1 (START)	1112	Compressor block 1 - oil low level alarm
28.03.2022, 14:14	44648593268,7037	0 (STOP)	1082	Compressor block 2 is not ready
28.03.2022, 14:14	44648593268,7037	0 (STOP)	1113	Compressor block 2 - oil low level alarm
28.03.2022, 14:15	44648594298,6458	0 (STOP)	1112	Compressor block 1 - oil low level alarm
28.03.2022, 14:15	44648594310,0926	0 (STOP)	1081	Compressor block 1 is not ready
28.03.2022, 14:15	44648594425,4861	1 (START)	1139	Compressor block 3 - Compressor 1 motor failure
28.03.2022, 14:16	44648594448,3796	1 (START)	1142	Compressor block 3 - Compressor 2 motor failure
28.03.2022, 14:16	44648594575,6945	1 (START)	1130	Compressor block 2 - Compressor 1 motor failure
28.03.2022, 14:16	44648594830,1157	1 (START)	1133	Compressor block 2 - Compressor 2 motor failure
28.03.2022, 14:17	44648595605,6366	1 (START)	1136	Compressor block 2 - Compressor 3 motor failure
28.03.2022, 14:17	44648595674,2361	0 (STOP)	1142	Compressor block 3 - Compressor 2 motor failure
28.03.2022, 14:17	44648595685,8796	1 (START)	1083	Compressor block 3 is not ready
28.03.2022, 14:17	44648595685,8796	0 (STOP)	1139	Compressor block 3 - Compressor 1 motor failure
28.03.2022, 14:17	44648595743,9005	0 (STOP)	1083	Compressor block 3 is not ready
28.03.2022, 14:18	44648595894,456	0 (STOP)	1130	Compressor block 2 - Compressor 1 motor failure
28.03.2022, 14:18	44648595905,9722	0 (STOP)	1133	Compressor block 2 - Compressor 2 motor failure
28.03.2022, 14:18	44648596114,2245	0 (STOP)	1136	Compressor block 2 - Compressor 3 motor failure
28.03.2022, 14:39	44648610785,3241	1 (START)	1082	Compressor block 2 is not ready
28.03.2022, 14:39	44648610785,3241	1 (START)	1108	Compressor block 2 - phase monitor alarm
28.03.2022, 14:42	44648612691,9097	0 (STOP)	1082	Compressor block 2 is not ready
28.03.2022, 14:42	44648612691,9097	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
28.03.2022, 14:44	44648614184,1898	1 (START)	1082	Compressor block 2 is not ready
28.03.2022, 14:44	44648614184,1898	1 (START)	1108	Compressor block 2 - phase monitor alarm
28.03.2022, 15:01	44648625720,0116	0 (STOP)	1082	Compressor block 2 is not ready
28.03.2022, 15:01	44648625720,0116	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
28.03.2022, 15:01	44648625928,3333	1 (START)	1082	Compressor block 2 is not ready
28.03.2022, 15:01	44648625928,3333	1 (START)	1108	Compressor block 2 - phase monitor alarm
28.03.2022, 15:13	44648634464,213	0 (STOP)	1082	Compressor block 2 is not ready
28.03.2022, 15:13	44648634464,213	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
28.03.2022, 15:13	44648634534,2593	1 (START)	1082	Compressor block 2 is not ready
28.03.2022, 15:13	44648634534,2593	1 (START)	1108	Compressor block 2 - phase monitor alarm
28.03.2022, 15:18	44648637852,0023	0 (STOP)	1108	Compressor block 2 - phase monitor alarm
28.03.2022, 15:18	44648637863,4607	0 (STOP)	1082	Compressor block 2 is not ready